

Annual Drinking Water Quality Report

The Water Works Board of the City of Vincent

January-December 2022

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (USEPA) and the Alabama Department of Environmental Management (ADEM) drinking water health standards. Your local water officials vigilantly safeguard its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standards. We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is a spring, which draws water from the Knox Aquifer. The water we supply to our customers requires no specialized treatment. However, Chlorine is added to the water as disinfectant and the required residual is maintained to protect your drinking water from any possible outside contaminants. We also purchase a portion of our water from New London Water, Sewer, and FPA whose water sources are two wells which pump from the Knox Aquifer.

The Vincent Water Board routinely completes a water storage facility inspection plan and utilizes a Bacteriological Monitoring Plan and a Cross Connection Policy is in place to insure good safe drinking water for our customers. We have completed a Source Water Assessment Plan, which is available at our office for review. This report provides information about potential sources of contamination and is set up to help protect our source.

We want our valued customers to be informed about their water utility. If you want to learn more, please visit our website www.vincentwaterboard.com or attend any of our regularly scheduled Board meetings. They are held at 6:00pm on the 2nd Monday of the month at the The Water Works Board of the City of Vincent office, located at 35 Florey Street.

The members of the Board of Directors are: Stan Elliott, Chairman James Latimer, Co-Chairman
Evelyn Finn, Secretary/Treasurer Frederick Kidd, Board Member Andy Barber, Board Member

Important Drinking Water Definitions:

Action Level (AL) - The concentration of a contaminant that triggers treatment or other requirements that a water system shall follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below, which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Millirems per year (mrem/yr) - Measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU) - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Non-Detects (ND) - Laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/L) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg/L) - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (ng/L) - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (pg/L) - One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Threshold Odor Number (T.O.N.) - The greatest dilution of a sample with odor-free water that still yields a just-detectable odor.

Variance & Exemptions - ADEM or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Explanation of reasons for variance/exemptions

Based on a study conducted by ADEM with the approval of the EPA a statewide waiver for the monitoring of asbestos and dioxin was issued. Thus, monitoring for these contaminants was not required.

The Vincent Water Board routinely monitors for contaminants in your drinking water according to Federal and State laws. Unless otherwise noted, the data presented in the following tables show the results of our monitoring period of January 1st to December 31st, 2022.

Table of Primary Contaminants

At high levels some primary contaminants are known to pose a health risk to humans. The table provides a quick glance of any primary contaminant detection.

CONTAMINANT	MCL	Vincennes	New London	CONTAMINANT	MCL	Vincennes	New London	CONTAMINANT	MCL	Vincennes	New London
Coliform Bacteria	< 5%	ND	ND	Selenium (ppb)	30	ND	ND - 1.5	Endrin (ppb)	TT	ND	ND
Fecal Coliform & E. coli	0	ND	ND	Total Chlorine (ppb)	2	ND	ND - 0.14	Endrin (ppb)	700	ND	ND
Chlorine (ppm)	4	ND	2.48	Organic Chlorine (ppb)	2	ND	200-2022	Endrin (ppb)	50	ND	ND
Alpha Chlordane (ppb)	15	0.9+4.7	1.23	Arochlor 1248 (ppb)	2	ND	ND	Endrin (ppb)	700	ND	ND
Combined Arochlors (ppb)	5	0.8+4.0	0.39	Arochlor 1254 (ppb)	3	ND	ND	Endrin (ppb)	400	ND	ND
Organic Chlorine (ppb)	90	ND	ND	Arochlor 1260 (ppb)	5	ND	ND	Endrin (ppb)	200	ND	ND
Asbestos (MFL)	7	ND	ND	Arochlor 1261 (ppb)	2	ND	ND	Endrin (ppb)	1	ND	ND
Barium (ppm)	2	0.02	0.01	Arochlor 1262 (ppb)	2	ND	ND	Endrin (ppb)	500	ND	ND
Beryllium (ppb)	4	ND	ND	Arochlor 1263 (ppb)	2	ND	ND	Endrin (ppb)	500	ND	ND
Bromine (ppb)	10	ND	ND	Arochlor 1264 (ppb)	2	ND	ND	Endrin (ppb)	4	ND	ND
Cadmium (ppb)	5	ND	ND	Arochlor 1265 (ppb)	2	ND	ND	Endrin (ppb)	100	ND	ND
Chlorine (ppm)	4	ND	ND	Arochlor 1266 (ppb)	2	ND	ND	Endrin (ppb)	5	ND	ND
Chlorine (ppm)	4	1.10	0.96	Arochlor 1267 (ppb)	2	ND	ND	Endrin (ppb)	1	ND	ND
Chlorine (ppm)	600	ND	ND	Arochlor 1268 (ppb)	2	ND	ND	Endrin (ppb)	TT	ND	ND
Chlorine (ppm)	4	ND	ND	Arochlor 1269 (ppb)	2	ND	ND	Endrin (ppb)	80	5.00	ND
Chromium (ppb)	100	ND	0.54	Arochlor 1270 (ppb)	2	ND	ND	Endrin (ppb)	3	ND	ND
Copper (ppm)	AL-1.3	0.09	ND - 0.004	Arochlor 1271 (ppb)	2	ND	ND	Endrin (ppb)	50	ND	ND
Cyanide (ppb)	200	ND	ND	Arochlor 1272 (ppb)	2	ND	ND	Endrin (ppb)	70	ND	ND
Dissolved Oxygen	4	ND	0.03	Arochlor 1273 (ppb)	2	ND	ND - 0.08	Endrin (ppb)	200	ND	ND
Lead (ppb)	AL-15	ND	ND - 1.8	Arochlor 1274 (ppb)	2	ND	ND	Endrin (ppb)	5	ND	ND
Manganese (ppb)	2	ND	ND	Arochlor 1275 (ppb)	2	ND	ND	Endrin (ppb)	5	ND	ND
Nitrate (ppm)	10	0.28	0.23	Arochlor 1276 (ppb)	2	ND	ND - 0.38	Endrin (ppb)	2	ND	ND
Nitrite (ppm)	1	ND	ND	Arochlor 1277 (ppb)	2	ND	ND	Endrin (ppb)	10	ND	ND
Total Nitrate & Nitrite	10	0.28	0.23	Arochlor 1278 (ppb)	2	ND	ND	Endrin (ppb)			

Table of Secondary and Unregulated Contaminants

Secondary Drinking Water Standards are guidelines regulating contaminants that may cause cosmetic effects (such as taste, color, or odor) in drinking water. ADEMR Secondary Drinking Water Standards established in state regulations applicable to water systems required to monitor for the various components. Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the need for unregulated contaminants in drinking water and whether future regulation is warranted.

CONTAMINANT	MCL	Vincennes	New London	CONTAMINANT	MCL	Vincennes	New London	CONTAMINANT	MCL	Vincennes	New London
Aluminum	0.2	108.00	ND	Fluoride	0.5	ND	ND	Silver	7	ND	ND - 0.35
Chloride	250	2.10	1.73	Iron	0.3	ND	ND	Sulfate	70	0.66	0.95
Copper (FCU)	15	5.00	ND	Manganese	75	10.90	8.25	Total Dissolved Solids	100	105	148.00
Copper	1	0.0042	ND	Odor (T.O.N.)	5	ND	ND	Zinc	5	ND	1.22
Calcium	N/A	26.80	94.00	pH (SU)	N/A	7.20	7.30	Temperature (°C)	N/A	40.70	25.00
Carbon Dioxide	N/A	5.3	1.70	Sodium	N/A	0.85	0.87	Total Alkalinity	N/A	126	105.50
Manganese	0.05	0.03	ND	Specific Conductance (umhos)	< 500	215.00	219.50	Total Hardness (as CaCO3)	N/A	114	112.00
1,1-Dichloroethane	N/A	ND	ND	Bromobenzene	N/A	ND	ND	Hexachlorobutadiene	N/A	ND	ND
1,1,2-Trichloroethane	N/A	ND	ND	Bromochlorobenzene	N/A	ND	ND	Isoprene	N/A	ND	ND
1,1-Dibromoethane	N/A	ND	ND	Bromodichlorobenzene	N/A	ND	ND	M-Dichlorobenzene	N/A	ND	ND
1,2,4-Trichlorobenzene	N/A	ND	ND	Bromobromobenzene	N/A	ND	ND	M-Xylene	N/A	ND	ND
1,2,3-Trichlorobenzene	N/A	ND	ND	Bromonitrobenzene	N/A	ND	ND	Methylchloroform	N/A	ND	ND
1,2,4-Trichlorobenzene	N/A	ND	ND	Chlorobenzene	N/A	ND	ND	Methylacetone	N/A	ND	ND
1,3-Dichlorobenzene	N/A	ND	ND	Chloroethane	N/A	ND	ND	M-Toluene	N/A	ND	ND
1,3-Dichlorobenzene	N/A	ND	ND	Chloroethene	N/A	ND	ND	N-Butylbenzene	N/A	ND	ND
1,3,5-Trichlorobenzene	N/A	ND	ND	Chloroethyne	N/A	2.50	ND	N-Propylbenzene	N/A	ND	ND
2,2-Dichloropropane	N/A	ND	ND	Chloroethane	N/A	ND	ND	O-Chlorobenzene	N/A	ND	ND
2-Bromochlorobenzene	N/A	ND	ND	Dibromochlorobenzene	N/A	ND	ND	P-Chlorobenzene	N/A	ND	ND
Athene	N/A	ND	ND	Dibromobenzene	N/A	ND	ND	P-Toluene	N/A	ND	ND
Athene Sulfone	N/A	ND	ND	Dibromodichlorobenzene	N/A	ND	ND	Pyrene	N/A	ND	ND
Athene Sulfone	N/A	ND	ND	Dibromodichlorobenzene	N/A	ND	ND	Sec-Butylbenzene	N/A	ND	ND
Athene Sulfone	N/A	ND	ND	Dibromodichlorobenzene	N/A	ND	ND	Tert-Butylbenzene	N/A	ND	ND

PFAS Compounds											
CONTAMINANT	RESULTS	UNITS	CONTAMINANT	RESULTS	UNITS	CONTAMINANT	RESULTS	UNITS			
11CL-PFOIDS	ND	ug/L	Perfluorodecanoic Acid	ND	ug/L	Perfluorooctanoic Acid	ND	ug/L			
9CL-PFOIDS	ND	ug/L	Perfluorohexanoic Acid	ND	ug/L	Perfluorotridecanoic Acid	ND	ug/L			
ADONA	ND	ug/L	Perfluorododecanoic Acid	ND	ug/L	Perfluorotridecanoic Acid	ND	ug/L			
HFPO-DA	ND	ug/L	Perfluorododecanoic Acid	ND	ug/L	Perfluoroundecanoic Acid	ND	ug/L			
NEFO-SAA	ND	ug/L	Perfluorododecanoic Acid	ND	ug/L	Total PFAs	ND	ug/L			
NMFO-SAA	ND	ug/L	Perfluorododecanoic Acid	ND	ug/L						
Perfluorobutanesulfonic Acid	ND	ug/L	Perfluorooctanesulfonic Acid	ND	ug/L						

Table of Detected Drinking Water Contaminants

CONTAMINANT	MCL G	MCL	Range		Vincent	New London	Amount Detected	Likely Source of Contamination
Microbiological Contaminants								
Turbidity	0	TT			0.25	0.25	NFD	Soil runoff
Radioisotopic Contaminants								
Beta particles and photon	0	4			ND	2.48	uSv/yr	Decay of natural and man-made deposits
Alpha emitters	0	15			0.8-0.7	1.22	pCi/L	Erosion of natural deposits
Combined Radium 226 & 228	0	5			0.8-0.7	0.39	pCi/L	Erosion of natural deposits
Inorganic Contaminants								
Barium	2	2	ND	-	0.02	0.02	0.01 ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chlorite	MRL/G 4	MRL/L 4	0.50	-	1.10	1.10	0.96 ppm	Water additive used to control microbes
Chromium	100	100	ND	-	ND	ND	0.34 ppb	Discharge from steel and pulp mills; erosion of natural deposits
Copper	1.3	10 Sites AL=1.3	No. of Sites above action level 0		0.09	ND - 0.004	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride	4	4	ND	-	0.02	0.02	0.03 ppm	Water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories
Lead	0	10 Sites AL=15	No. of Sites above action level 0		ND	ND - 1.8	ppb	Corrosion of household plumbing systems; erosion of natural deposits
Nitrates (as N)	10	10	ND	-	0.28	0.23	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Total Nitrate & Nitrite	10	10	ND	-	0.28	0.23	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	50	50	ND	-	ND	ND	ppb	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Thallium	0.5	2	ND	-	ND	ND	ppb	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
Organic Contaminants								
Di(2-ethylhexyl) phthalates	0	6	ND	-	ND	ND	ND - 0.08 ppb	Discharge from rubber and chemical factories
Diquat	20	20	ND	-	ND	ND	ND - 0.38 ppb	Runoff/leaching from herbicide use
Halocetic Acids (HAA5)	0	60	1.30	-	2.30	1.8avg	ND ppb	By-product of drinking water chlorination
Total trihalomethanes (TTHM)	0	80	2.50	-	8.70	5.6avg	0.20 ppb	By-product of drinking water chlorination
Secondary Contaminants								
Chloride	N/A	250	ND	-	2.10	2.10	1.73 ppm	Naturally occurring in the environment or as a result of agricultural runoff
Iron	N/A	0.3	ND	-	ND	ND	ND ppm	Erosion of natural deposits
Magnesium	N/A	0.05	ND	-	10.90	10.90	ND ppm	Erosion of natural deposits
Silver	N/A	0.1	ND	-	ND	ND	ND ppm	Erosion of natural deposits
Sulfate	N/A	250	ND	-	0.86	0.86	0.95 ppm	Naturally occurring in the environment
Total Dissolved Solids	N/A	500	ND	-	105.00	105.00	148.00 ppm	Erosion of natural deposits
Zinc	N/A	5	ND	-	ND	ND	1.22 ppm	Erosion of natural deposits
Special Contaminants								
Copper	N/A	1	ND	-	0.00	0.00	ND ppm	Erosion of natural deposits; leaching from pipes
Calcium	N/A	N/A	ND	-	26.90	26.90	34.00 ppm	Erosion of natural deposits
Carbon Dioxide	N/A	N/A	ND	-	5.30	5.30	1.70 ppm	Erosion of natural deposits
Manganese	N/A	N/A	ND	-	0.03	0.03	8.35 ppm	Erosion of natural deposits
pH	N/A	N/A	7.70	-	7.80	7.80	7.30 SU	Naturally occurring in the environment or as a result of treatment with water additives
Sodium	N/A	N/A	ND	-	0.86	0.86	0.87 ppm	Naturally occurring in the environment
Specific Conductance	N/A	<500	ND	-	215.00	215.00	219.50 uS/cm	Naturally occurring in the environment or as a result of treatment with water additives
Temperature	N/A	N/A	ND	-	40.70	40.70	25.00 °C	Naturally occurring in the environment
Total Alkalinity	N/A	N/A	ND	-	126.00	126.00	105.50 ppm	Erosion of natural deposits
Total Hardness (as CaCO3)	N/A	N/A	ND	-	112.00	112.00	107.00 ppm	Naturally occurring in the environment or as a result of treatment with water additives

The Water Works Board of the City of Vincent
35 Florey Street
P.O. Box 300
Vincent, AL 35178

PRSRRT FIRST CLASS
U.S. POSTAGE PAID
VINCENT, AL
VINCENT WATER BOARD
PERMIT No. 101

KERRY BONIFAY
882 HIGHWAY 81
VINCENT, AL 35178-7906

General Information

Violation - The Vincent Water Works Board has incurred a (SOC) Synthetic Organic Compounds reporting non-compliance. The non-compliance resulted from a failure to submit the August 30, 2022, results by October 10, 2022. ADEM Admin. Code r. 335-7-2-.20(1)(a) states, "the supplier of water shall report to the Department the results of any test, measurement or analysis within the first 10 days following the month in which the results is received or the first 10 days following the end of the required monitoring period as stipulated by the Department, whichever is shortest." Vincent Water Works Board takes pride in your water quality; therefore, this violation was incurred due to our testing laboratory failure to submit the sample results on time to the Alabama Department of Environmental Management (ADEM). Our testing laboratory is responsible for the submission of test results directly to ADEM. Vincent Water Works Board water samples were taken and tested within the required testing period as mandated by ADEM. Vincent Water Works Board has implemented steps to ensure the testing laboratory is submitting the results to ADEM in a timely manner to avoid this type of violation in the future. If you have any questions, please feel free to contact Kerry Bonifay (205) 369-8372.

As you can see by the tables, our system had no monitoring violations of allowable limits of contaminants in drinking water. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. The EPA has determined that your water IS SAFE at these levels. MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Vincent Water Board is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and it can pick up substances resulting from the presence of animals or from human activities.

Total Coliform: The Total Coliform Rule requires water systems to meet a stricter limit for coliform bacteria. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public by newspaper, television or radio. To comply with the stricter regulation, we have increased the average amount of chlorine in the distribution system.

Some people may be more vulnerable to contaminants in drinking water than the general population. People who are immuno-compromised such as cancer patients undergoing chemotherapy, organ transplant recipients, HIV/AIDS positive or other immune system disorders, some elderly, and infants can be particularly at risk from infections. People at risk should seek advice about drinking water from their health care providers. EPA (Environmental Protection Agency)/CDC (Center of Disease Control) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline. All Drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

For more information, contact:

The Water Works Board of the City of Vincent
35 Florey Street P O Box 300
Vincent, AL 35178
Telephone: (205) 672-2878
Monday - Friday
8:00 AM - 4:00 PM